

Message Text

CONFIDENTIAL

PAGE 01 STATE 123821

70

ORIGIN EUR-25

INFO OCT-01 ADP-00 OCL-00 SY-10 OC-06 CCO-00 FBO-01 RSC-01

/044 R

DRAFTED BY EUR/ EX - JCGARON: LM

6/22/73 - EXT. 23327

APPROVED BY EUR/ EX - JMCLARK

EUR/ EX - LDRUSSELL

EUR/ EX - RGDEASON (DRAFT)

EUR/ EX - FBWIGGINS

OC/ L - SROGALA (SUBS.)

SY/ FO - RMCCARTHY (DRAFT)

A/ FBO - PWSTANGE (INFO.)

OC/ S - RRAPIER (DRAFT)

----- 047049

R 252048 Z JUN 73

FM SECSTATE WASHDC

TO AMEMBASSY MOSCOW

INFO AMEMBASSY BONN

AMCONSUL FRANKFURT

AMEMBASSY HELSINKI

C O N F I D E N T I A L STATE 123821

E. O. 11652: XGDS2

TAGS: AFSP, ABLD, ASEC, ACOM

SUBJ: LENINGRAD OFFICE BUILDING

BONN FOR RCO. FRANKFURT FOR RSS.

REF: MOSCOW 6617

1. BUREAU WILL FUND NEEDED MATERIALS FOR CONSTRUCTION OF
C AND R AREA IN FY 74 IF FY 73 FUNDS NOT AVAILABLE.

2. VINYL TILES TO BE PROCURED LOCALLY OR FROM THIRD
COUNTRY BY ADVANCE PARTY. FY 74 FUNDS WILL BE MADE AVAIL-
ABLE FOR PURCHASE. PLEASE PROVIDE BUREAU WITH ESTIMATE
CONFIDENTIAL

CONFIDENTIAL

PAGE 02 STATE 123821

OF COSTS OF MATERIALS AND INSTALLATION.

3. ADVANCE PARTY TO PROCURE CURTAINS AND RODS FOR 4 TH FLOOR.

4. PHYSICAL DIMENSIONS EACH EDWARDS CHILLER UNIT, 46 INCHES WIDE, 41 INCHES LONG AND 51 INCHES HIGH. WEIGHT EACH UNIT EMPTY APPROX. 900 LBS. PUMPS AND EXTERNAL PIPING MAY BE REMOVED IF NECESSARY FOR ENTRY NARROW OPENINGS. EDWARDS CHILLER MANUAL BEING POUCHED MOSCOW AND HELSINKI.

5. THE EXISTING VENTS IN COMM CENTER ARE PRIME SECURITY TARGETS DUE NATURE OF OPENING, AND EASE OF ACCESSIBILITY

FROM ADJOINING BUILDINGS AND ATTIC AREA. BLOCK VENTS WHERE POSSIBLE. ADVISE DEPT. WHICH IMPOSSIBLE BLOCK. SUITABLE COUNTER MEASURE TREATMENT WILL BE DEVELOPED.

6. COMMUNICATIONS AREA FRESH AIR INTAKE SUFFICIENT FOR NUMBER PERSONS OCCUPYING AREA. INSTALL AIR INTAKE FAN PER SPECIFICATIONS PARA. C8 (14).

7. UNCLASSIFIED DRAWINGS NUMBER LENINGRAD NO. 1 AND NO. 2 DATED 19 JULY 1973 TITLED " PROPOSED GENERATOR ROOM LAYOUT GENERATOR NO. 2 AND " PROPOSED POWER LAYOUT GENERATOR ROOM NO. 1 AND 2" WERE PROVIDED SOVIETS. THEY INDICATE METHOD OF GENERATOR ELECTRICAL POWER INSTALLATION AND MAIN POWER RUN TO FOURTH FLOOR. NORMAL POWER SOURCE FOR FOURTH AND FIFTH FLOOR MAIN POWER PANEL MUST TERMINATE IN COMMUNICATIONS GENERATOR ROOM POWER TRANSFER SWITCH. PREFERABLE INSTALL ONLY ONE SET OF POWER FEEDER CABLES TO FOURTH AND FIFTH FLOOR. INSTALL POWER AS SHOWN DRAWING L6. FEEDERS FROM GENERATOR ROOM PRESENTLY TERMINATED IN AREA ABOVE GENERATOR ROOM SHOULD BE EXTENDED TO ROOM 5 POWER PANEL " A" AS SHOWN ON DRAWING L3, SUGGEST SEABEES INSTALL.

8. ACCESS TO FIFTH FLOOR ATTIC TAKEN INTO ACCOUNT DURING PLANNING. MAINTENANCE REQUIRED THIS AREA WILL BE ACCOMPLISHED BY SEABEES.

9. SPECIFICATIONS PARA. 8 E (1), 8 F, AND 8 F (1) INDICATE
CONFIDENTIAL

CONFIDENTIAL

PAGE 03 STATE 123821

120 VOLT CIRCUITS. THESE REQUIREMENTS ARE FOR COMMUNICATIONS EQUIPMENT AND COMMUNICATIONS WORK BENCH. STEP DOWN TRANSFORMER (5 KW) BEING INCLUDED IN COMMUNICATIONS EQUIPMENT SHIPMENT. ROGERS

CONFIDENTIAL

NNNNMAFVVZCZ

*** Current Handling Restrictions *** n/a

*** Current Classification *** CONFIDENTIAL

Message Attributes

Automatic Decaptioning: X
Capture Date: 01 JAN 1994
Channel Indicators: n/a
Current Classification: UNCLASSIFIED
Concepts:
Control Number: n/a
Copy: SINGLE
Draft Date: 25 JUN 1973
Decaption Date: 01 JAN 1960
Decaption Note:
Disposition Action: RELEASED
Disposition Approved on Date:
Disposition Authority: boyleja
Disposition Case Number: n/a
Disposition Comment: 25 YEAR REVIEW
Disposition Date: 28 MAY 2004
Disposition Event:
Disposition History: n/a
Disposition Reason:
Disposition Remarks:
Document Number: 1973STATE123821
Document Source: CORE
Document Unique ID: 00
Drafter: JCGARON: LM
Enclosure: n/a
Executive Order: RR
Errors: n/a
Film Number: n/a
From: SECSTATE WASHDC
Handling Restrictions: n/a
Image Path:
ISecure: 1
Legacy Key: link1973/newtext/t19730631/aaaajrhs.tel
Line Count: 117
Locator: TEXT ON-LINE
Office: ORIGIN EU
Original Classification: CONFIDENTIAL
Original Handling Restrictions: n/a
Original Previous Classification: n/a
Original Previous Handling Restrictions: n/a
Page Count: 3
Previous Channel Indicators:
Previous Classification: CONFIDENTIAL
Previous Handling Restrictions: n/a
Reference: n/a
Review Action: RELEASED, APPROVED
Review Authority: boyleja
Review Comment: n/a
Review Content Flags:
Review Date: 09 AUG 2001
Review Event:
Review Exemptions: n/a
Review History: RELEASED <09-Aug-2001 by shawdg>; APPROVED <13-Sep-2001 by boyleja>
Review Markings:

Declassified/Released
US Department of State
EO Systematic Review
30 JUN 2005

Review Media Identifier:
Review Referrals: n/a
Review Release Date: n/a
Review Release Event: n/a
Review Transfer Date:
Review Withdrawn Fields: n/a
Secure: OPEN
Status: <DBA CORRECTED> wfs 980302
Subject: LENINGRAD OFFICE BUILDING
TAGS: ABLD, ACOM, AFSP, ASEC, FI, GM, UR
To: BONN
FRANKFURT
HELSINKI
MOSCOW
Type: TE
Markings: Declassified/Released US Department of State EO Systematic Review 30 JUN 2005